



PURCHASING DEPARTMENT

September 2, 2010

ADDENDUM NO. 1

BID NO. 2010-088-5206

Services to Furnish and Replace Emergency Generator Control Panels

WHEREAS, the bid is amended as follows:

1) **To include: SECURITY FOR FAITHFUL PERFORMANCE:**

PERFORMANCE BOND: Chapter 2253.01 of the Texas Government Code governs the requirements for performance and payment bonds for government entities.

A performance bond is required if the contract is in excess of \$100,000.

A Bid Bond is also required if the contract is in excess of \$25,000 (*Bid Bond Shall be submitted with bidders Bid Package.*)

A Payment bond is required if the contract is in excess of \$25,000. The bonds shall be executed prior to beginning work on the project and must be executed by a corporate surety or sureties in accordance with the Texas Insurance Code.

Bonds shall be executed by a duly authorized surety company satisfactory to Dallas County. Dallas County will accept only those bonds executed by those surety companies listed in Circular 570 "Surety Companies Acceptable on Federal Bonds published in the Federal Register, U.S. Department of the Treasury.

No sureties will be accepted by Dallas County who are now in default or delinquent on any bonds or who are interested in any litigation against Dallas County. All bonds shall be executed by corporate surety authorized to do business in the State of Texas.

Each bond shall be executed by the Contractor and the Surety. Each surety shall designate an agent resident in the State of Texas to whom any requisite notices may be delivered and on whom service of process may be had in matters arising out of such surety ship.

A good and sufficient Bond in an amount equal to 100 percent of the approximate total amount of the Contract, as evidenced by the Proposal tabulation, or otherwise guaranteeing the full and faithful execution of the Work and performance of the Contract in accordance with the Plans, Specifications and Contract Documents, including any extensions thereof, for the protection of Dallas County.

This bond shall provide for the repair, and for maintenance attendant thereto, of all defects due to faulty materials, workmanship, defects, and failures that may appear within a period of one year from the date of completion and acceptance of the Work by the Commissioners Court.

In the event the contract is prematurely terminated due to non-performance and/or contractor request, Dallas County reserves the right to act on the performance bond and/or seek monetary restitution. In the event civil suit is filed to enforce this provision, Dallas County will seek it's attorney's fees and cost of suit from the Contractor.

All bonds shall be delivered to the Dallas County Purchasing Department, c/o Carmen Nixon, 509 Main Street, Room 623, Dallas, Texas 75202, within 30 days after award of the contract.

Dallas County will disburse no payments for goods and or services provided unless a good and sufficient bond is on file with the County.

2. Page 12, Item 3 “Technical and Functionality Requirements” – all features for the engine and/or generator will include STANDARD Features only meeting NFPA 110, no customization features are required. As a result and as applicable the following features are hereby deleted:
 - Standard Controls – item 15
 - Standard Protection Controls:
 - “Warnings” items d, g, h, i, j
 - “Shutdowns” items c, f, h, j, l, m

3. Awarded firm is responsible for setting up and disconnecting of temporary generators as needed to ensure adequate power is supplied to respective areas.

All other specifications of the original bid remain the same.

This addendum is hereby acknowledged, understood and considered in our bid.

Signature: _____

Name: _____

Company: _____ Date: _____