



October 27, 2009

Addendum No. 1
Bid No. 2010-012-4715
Purchase and Installation of Three (3) New 5 Ton Commercial
Unitary Gas/Electric Roof Top Package Units

Whereas, Bid Specifications, Page 12, Item 4.12, is hereby amended to read as follows:

4.12 Contractor shall furnish and install new plenum and ductwork to insure a fully balanced and operational system. **Note: One (1) unit currently has plenums that are supported by the existing package unit. Contractor is solely responsible for supporting the existing plenums from underneath to allow for removal of the existing unit. The other two (2) units are side discharge**

Whereas, Bid Specifications, Page 12, Item 4.16, is hereby amended to read as follows:

4.16 Contractor shall furnish and install all new condensate line, pipe supports, conduit supports, and curbs and curb adaptors to the new roof top units. Curbs and curb adaptors are not required on side discharge units unless they required by the manufacturer of the new RTU that your company is proposing. It is the responsibility of the Contractor to determine if curbs and curb adaptors are required based on the type of new replacement units being proposed for this project.

Except as provided herein/above, all other specification requirements of the original bid referenced shall remain unchanged in and full force and effect. This addendum should be signed and returned with your proposal package on or before Monday, November 2, 2009; 2:00 P.M., CST

This addendum is hereby acknowledged, understood and considered in our proposal.

Printed Name: _____

Signature of Authorized Representative: _____

Title: _____

Company: _____

Date: _____