



**DALLAS COUNTY
PURCHASING DEPARTMENT**

Records Building, 500 Elm Street, Suite 5500
Dallas, Texas 75202

**Michael Frosch
Purchasing Director**

January 15, 2026

ADDENDUM #2

**RFQ 2026-009-7094 DALLAS COUNTY HEALTH AND HUMAN SERVICES (DCHHS) SWITCHGEAR
REPLACEMENT SOLICITATION**

Whereas,

By the way of this addendum, Dallas County Purchasing will answer the question presented at the Microsoft Teams Pre-bid meeting on January 14, 2026.

Question: What Breakers does Dallas County require for this project?

Answer: The county requires withdrawable/inline (Draw-Out) Breakers.

Except as provided herein/above, all other specification requirements of the original solicitation referenced shall remain unchanged in full force and effect. This addendum should be signed and returned with your Solicitation package on or before 2/19/2026, @ 2 PM (CST).